

**Construction of Improvements at Nolan Field  
Ansonia, Connecticut  
April 17, 2025**

**BIDDER QUESTIONS WITH RESPONSES**

The following questions were submitted by bidders, response from the City/Designer are in

*Red and italics.*

1. IES has various classifications for light levels, based on class of facility. Which class is specified for each facility? Number and size of grid points per facility?

*The lighting for this facility shall be designed for High School level of play.*

2. Is there a warranty for the sports lighting? A couple of the existing poles are in difficult locations to access, which could be costly for the town going forward, without a parts and labor warranty

*A warranty shall be provided with this lighting system.*

3. If you require remoting the drivers, and surge protection, to the bottom of the poles, cost of ownership is dramatically reduced

*The system shall be designed with a remote surge protection.*

4. Do you require any local references for the sports lighting? At a minimum 10 similar installations, in CT, should be provided

*References shall be submitted with a minimum of five (5) in close proximity to this site. The lighting system shall also be American made.*